

# CHP 4

## Data

|                      |   |
|----------------------|---|
| Manufacturer         | Haase                                     |
| Container aggregate  | completely                                |
| Manufacturing number | 2200633                                   |
| Type                 | TBG 620 V12                               |
| Engine performance   | 762kW                                     |
| steering             | Combustion chamber temperature controlled |
| generator            | Stamford                                  |
| Performance          | 737kW                                     |
| Construction year    | 1999                                      |
| Operating hours      | 150203                                    |

## Maintenance status until January 2023

|                   |                                   |
|-------------------|-----------------------------------|
| April 28, 2022    | New EWA control                   |
| May 2, 2022       | LS switch repaired                |
| June 1, 2022      | Eliminate oil losses              |
| July 12, 2022     | Motor protection switch replaced  |
| August 17, 2022   | MWM E50 with extensions           |
| January 17, 1900  | Improve EWA engine control        |
| December 21, 2022 | MWM E40 and emissions measurement |
| January 13, 2023  | Emission measurement 22           |